



Product Service

# Attestation of Conformity

No. E8A 083414 0003 Rev. 00

**Holder of Certificate:** **ZhongShan ShangFang Instrument Meter Co.,Ltd**  
No.2, Huashi Road, Gangkou Town  
528400 Zhongshan, Guangdong  
PEOPLE'S REPUBLIC OF CHINA

**Name of Object:** **Temperature controller**  
**(digital display temperature controller)**

**Model(s):** **SF-ABCYZ**  
(A can 1-8, standing for the different control types of product models; BC can be 00-02, 04-06, standing for the different number of relay output and sensor; Y can be S or P, standing for the different means of wiring connection; Z can be N or blank, standing for the different means of relay and adaptor connection)

**Description of Object:** Rated input voltage: 230V~, 50Hz  
Rated input current: 20mA  
Overvoltage category: II

**Tested according to:** EN 60730-1:2011  
EN 60730-1:2016  
EN 60730-2-9:2010  
EN 60730-2-7:2010

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 64713120311601

**Date,** 2019-04-17 ( Tony Liu )

ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFIKAT ◆ 認證證書 ◆

A4 / 07.17